



SPECIAL SYSTEMS PLAN, MAIN LEVEL - AREA E




SCALE: 1/8" = 1'-0"

ADMM



KEY PLAN




Architecture Engineering Interiors

© 2007, DLR Group Inc., a Nebraska corporation

E3.15
10-05108-00
01-00-08
01-00-08
ADMM C-1, 17.08
ADMM C-1, 17.08
ADMM C-1, 17.08
ADMM C-1, 17.08

SPECIAL SYSTEMS PLAN, MAIN LEVEL - AREA E
CREIGHTON PREPARATORY SCHOOL
FITNESS CENTER ADDITION & RENOVATION

REISSUED 04.30.08
WITH ADDENDA
CC-1 TO CC-5
ATTACHMENT NO. E31
DATED APRIL 30, 2008



LEGEND NOTES

- GENERAL NOTES—THIS SHEET.
- SEE SHEET E3.06 FOR GENERAL NOTES.
 - PROVIDE IVORY COLORED SURFACE METAL RACKWAY AND VIDEO DEVICES FOR ALL EXISTING CONSTRUCTION (AREA C-0).
- NOTES—THIS SHEET.
- FIRE ALARM PRIME ANNUNCIATOR WITH MICROPHONE.
 - INTERCOM MASTER STATION, VERIFY LOCATION WITH OWNER.
 - INTERCOM MASTER STATION, VERIFY LOCATION WITH OWNER. AVAILABLE 120 VOLT POWER, CONNECT THROUGH LOCAL FA RELAY. CONTRACTOR'S OPTION TO REPLACE WAS DOOR HOLD SUPPLY WITH LOW VOLTAGE TYPE AND POWER FROM FA POWER CONNECT TO FIRE ALARM SYSTEM PER GENERAL NOTE "D".
 - EXISTING SHADE DAMPER PROVIDE DUCT DETECTOR AND PROVIDE LOW PROFILE INTERCOM SPEAKER HORN.
 - PROVIDE LOW PROFILE INTERCOM SPEAKER HORN.
 - MONITOR RELAY BASE FOR LOCAL RELEASE OF DOOR SWITCHES AS SPEC'ED.

NOTE:
INTERCOM SYSTEM: EQUIPMENT, MATERIALS AND LABOR OF THIS SYSTEM WILL BE PROVIDED BY OWNER. RACKWAY, BONES, POWER AND ASSOCIATED ELECTRICAL WORK SHALL BE PROVIDED BY ELECTRICAL CONTRACTOR. CONTRACTOR SHALL COORDINATE WITH OWNER, ELECTRICAL CONTRACTOR AND INTERCOM CONTRACTOR TO COORDINATE EXACT REQUIREMENTS OF REPLACEMENT SYSTEM PROVIDED BY OWNER.
SOUND SYSTEMS: EQUIPMENT, MATERIALS AND LABOR OF THIS SECTION WILL BE PROVIDED BY OWNER. RACKWAY, BONES, POWER AND ASSOCIATED ELECTRICAL WORK SHALL BE PROVIDED BY ELECTRICAL CONTRACTOR. CONTRACTOR SHALL COORDINATE WITH OWNER, ELECTRICAL CONTRACTOR AND SOUND SYSTEMS CONTRACTOR TO COORDINATE EXACT REQUIREMENTS OF REPLACEMENT SYSTEM PROVIDED BY OWNER.
SOUND SYSTEMS: EQUIPMENT, MATERIALS AND LABOR OF THIS SECTION WILL BE PROVIDED BY OWNER. RACKWAY, BONES, POWER AND ASSOCIATED ELECTRICAL WORK SHALL BE PROVIDED BY ELECTRICAL CONTRACTOR. CONTRACTOR SHALL COORDINATE WITH OWNER, ELECTRICAL CONTRACTOR AND SOUND SYSTEMS CONTRACTOR TO COORDINATE EXACT REQUIREMENTS OF REPLACEMENT SYSTEM PROVIDED BY OWNER.

